

NOTIFIED BODY No. 1488 INSTYTUT TECHNIKI BUDOWLANEJ CERTIFICATION DEPARTMENT



ul. FILTROWA 1, 00-611 WARSZAWA ph.: +48 (22) 57 96 167, +48 (22) 57 96 168, fax: +48 (22) 57 96 295 e-mail: certyfikacja@itb.pl, www.itb.pl

CERTIFICATE OF CONSTANCY OF PERFORMANCE 1488-CPR-0765/W

In compliance with Regulation 305/2011/EU of the European Parliament and of the Council of 9 March 2011 (the Construction Products Regulation or CPR), this certificate applies to the construction product:

Smoke duct sections KOD

with fire resistance class according to EN 13501-4:2016

E₆₀₀ 120 (h_o) S1500single

General identification, intended use, essential characteristics and parameters are described in the Annex No. Z-1488-CPR-0765/W which is an integral part of this certificate

Levels and classes of performance of the product are stated in the Annex No. Z-1488-CPR-0765/W which is an integral part of this certificate

placed on the market under the name or trade mark of:

Karpol Sp. z o.o. Al. Wojska Polskiego 66 64-920 Piła Poland

and produced in the manufacturing plant:

Karpol Sp. z o.o. Al. Wojska Polskiego 66 64-920 Piła Poland

This certificate attests that all provisions concerning the assessment and verification of constancy of performance described in Annex ZA of the standard:

EN 12101-7:2011

under system 1 for the performance set out in this certificate are applied and that the factory production control conducted by the manufacturer is assessed to ensure the constancy of performance of the construction product.

This certificate was first issued on 23.08.2019 (updated on 21.04.2020) and will remain valid as long as neither the harmonised standard, the construction product, the AVCP methods, nor the manufacturing conditions in the plant are modified significantly, unless suspended or withdrawn by the notified product certification body.

DEPUTY HEAD of the Certification Department

Piotr Maciejak, M.Sc. Eng.



DEPUTY DIRECTOR of Instytut Techniki Budowlanej

Anna Panek, M.Sc. Eng.