



**NOTIFIED BODY No. 1488
INSTYTUT TECHNIKI BUDOWLANEJ
CERTIFICATION DEPARTMENT**

ul. FILTROWA 1, 00-611 WARSZAWA
ph.: +48 (22) 57 96 167, +48 (22) 57 96 168, fax: +48 (22) 57 96 295
e-mail: certyfikacja@itb.pl, www.itb.pl



**CERTIFICATE OF CONSTANCY OF PERFORMANCE
1488-CPR-0764/W**

In compliance with Regulation 305/2011/EU of the European Parliament and of the Council of 9 March 2011 (the Construction Products Regulation or CPR), this certificate applies to the construction product:

**Smoke duct sections
KPD**

with fire resistance class according to EN 13501-4:2016

E₆₀₀ 120 (h_o) S1500single

General identification, intended use, essential characteristics and parameters are described in the Annex No. Z-1488-CPR-0764/W which is an integral part of this certificate

Levels and classes of performance of the product are stated in the Annex No. Z-1488-CPR-0764/W which is an integral part of this certificate

placed on the market under the name or trade mark of:

**Karpol Sp. z o.o.
Al. Wojska Polskiego 66
64-920 Piła
Poland**

and produced in the manufacturing plant:

**Karpol Sp. z o.o.
Al. Wojska Polskiego 66
64-920 Piła
Poland**

This certificate attests that all provisions concerning the assessment and verification of constancy of performance described in Annex ZA of the standard:

EN 12101-7:2011

under system 1 for the performance set out in this certificate are applied and that the factory production control conducted by the manufacturer is assessed to ensure the constancy of performance of the construction product.

This certificate was first issued on 23.08.2019 (updated on 13.10.2020) and will remain valid as long as neither the harmonised standard, the construction product, the AVCP methods, nor the manufacturing conditions in the plant are modified significantly, unless suspended or withdrawn by the notified product certification body.

HEAD
of the Certification Department

Katarzyna Hatowska, M.Sc. Eng.



DEPUTY DIRECTOR
of Instytut Techniki Budowlanej

Anna Panek, M.Sc. Eng.

Warsaw, 13.10.2020